

# DAYCARE FACILITY

<u><b>INDOOR</b></u>	<b>PASS</b>	<b>FAIL</b>	<b>PASS REINSP</b>
Hot water accessible to children not to exceed 110°			
Class "B" Fire extinguisher in kitchen and other cooking areas			
Posted Emergency Plan, including evacuation route			
Protective covers in/over electrical outlets			
No evidence of infestation (rodent or insect)			
Temperature between 65° and 82° (portable space heaters not permitted)			
Hot water pipes or other pipes accessible to children that are greater than 110° equipped with protective guards or insulated			
Natural or mechanical ventilation required			
Windows or doors used for ventilation screened & screen in good repair			
Doors or windows above ground floor that are accessible to children & open directly to outdoors have opening limited to 6" or less			
Operable telephone with a published telephone number			
Nearest hospital, poison control center, police, fire, police, & ambulance stations phone numbers posted by each phone			
First aid kit available but is inaccessible to children			
Floors, walls, ceiling, & other surfaces are clean, in good repair, and free from visible hazards. (Including no peeling paint)			
Room, halls, stairways, outdoor steps, porches, and ramps are well-lit			
Glass located in child care area to have visible strip			
At least 1 flushing toilet for every 15 toddler/preschool age children or 20 school-age children			
At least 1 working sink for every 25 toddler/preschool age children or every 30 school-age children located within or near the toilet area.			
A source of running water for handwashing must be present in infant and toddler diapering areas.			
Toilet/potty training chairs located in rooms separate from eating or cooking			
Stairs, halls, exits from rooms and facilities or any other means of egress unobstructed			
Doors or doorways that open to stairways without landings shall be restricted or removed			
Fireplaces, etc shall be securely screened or equipped with protective guards			
3 or more steps shall be equipped with a handrail and have a non-skid surface			

Name: \_\_\_\_\_

Permit No. \_\_\_\_\_

Address: \_\_\_\_\_

Date of Inspection: \_\_\_\_\_

\_\_\_\_\_

# DAYCARE FACILITY

<u><b>OUTDOOR</b></u>	<b>PASS</b>	<b>FAIL</b>	<b>PASS REINSP</b>
Outdoor equipment means that the protective surfacing material must be safe and shock absorbing for a fall from the highest designated play surface on a piece of equipment as specified in the United States Consumer Public Safety Commission's <i>Public Playground Safety Handbook</i> , Publication 325.			
Slides over 4' in height have guards on both sides			
Protective material with a diameter of less than 1" cannot be used in infant/toddler care areas			
Outdoor play area is clean, in good repair, and free from visible hazards			
Walkways free of ice, snow, leaves, equipment, etc.			
If unsafe conditions are in or near outdoor play space, a fence or natural barrier is required			
Porches are to be equipped with a handrail			
3 or more steps shall be equipped with a handrail			
Outdoor equipment that requires embedded mounting must be mounted over a loose-fill or unitary playground protective surface covering that meets the recommendations of the United States Consumer Product Safety Commission. The equipment must be anchored firmly and be in good repair.			
Ramps are to be equipped with handrails			

Name: \_\_\_\_\_

Permit No. \_\_\_\_\_

Address: \_\_\_\_\_

Date of Inspection: \_\_\_\_\_

\_\_\_\_\_